



A Unitil company

February 6, 2026

Nathan Dore  
Gas Safety Manager  
Maine Public Utilities Commission  
18 State House Station  
Augusta, ME 04333-0018

**RE: January 2026 – Leak & Odor Call Response, Facility Damage Due to Utility Error, and Leak and Odorant Report**

Dear Mr. Dore,

This report is in accordance with the Conditions placed on Maine Natural Gas (MNG) in the Stipulation of Docket No. 2007-335.

a. Leak & Odor Call Response:

Attachment 1 is a spreadsheet indicating the leak and odor call response times for the month of January 2026. The list includes calls during both working and non-working hours and includes those that may have involved problems with the customer's equipment and/or alarms. MNG's Emergency Call Center also dispatches our Technicians for Emergency Dig Safe notifications during non-working hours. Those responses are not listed on the attached spreadsheet.

b. Facility Damage Due to Utility Error:

There were not any incidents causing damage to MNG's facilities due to Utility Error in the month of January 2026.

c. Submit a Monthly Leak and Odorant Report:

Attachment 2 is a spreadsheet of Maine Natural Gas' odorant level readings for January 2026. Our Operations and Maintenance Procedures require that odorant be readily detectable at a concentration of 0.50% gas in air.

Below is the current status of leaks on MNG's system:

<b>Leak Type</b>	<b>No. of Leaks as of 01/01/2026</b>	<b>No. of Leaks Found in January 2026</b>	<b>No. of Leaks Repaired in January 2026</b>	<b># of Leaks Awaiting Repair as of 2/01/2026</b>
<b>Grade 1</b>	0	2	2	0
<b>Grade 2</b>	0	0	0	0
<b>Grade 3</b>	0	0	0	0
<b>Above Ground</b>	0	12	12	0

If you have any questions or require additional information, please do not hesitate to contact me.

Sincerely,



Joseph Gauthier, PE  
Principal Gas Engineer

Attachments:

Attachment 1 – January 2026 Emergency Response Summary

Attachment 2 – January 2026 Odorant Level Readings

cc: Joe Renda- Manager, Gas Distribution Operations, Unitil, via email  
Katherine Silver- Manager, Gas Compliance, Unitil, via email