

RISK MANAGEMENT BULLETIN

ALERT: FIRE SPRINKLER RECALL



We would like to make you aware of a voluntary recall of certain “Star” brand fire sprinklers manufactured from 1961 through 1976. These “dry-type” sprinklers could likely fail in a fire.

Risk Management recommends the following action on your part:

- Copy and send this bulletin to your maintenance managers at each of your facilities.**
- The maintenance manager should determine whether the facility contains any of these recalled sprinklers.**
- If the facility is equipped with any of these recall sprinklers, then a recall claim needs to be made to the manufacturer by your department.**

See the reverse side of this bulletin for more information.

The web site www.star-recall.com
is a valuable resource for information on this recall.

Call our office if you have any questions at all, or if we can be of assistance.